



Office for People With Developmental Disabilities

ANDREW M. CUOMO
Governor

THEODORE KASTNER, MD, MS
Commissioner

January 29, 2021

2021-2026 Specialized Water Treatment Services with Maintenance and Inspections in Richmond County Staten Island DDSOO – IFB SI 021121

Questions and Answers:

Below is a compilation of the questions received for the above referenced IFB. Questions that were repeated, or of a recurring nature, were consolidated. Thank you very much for your interest.

- 1. Question:** Who is the present water treatment contractor for this location and what is the yearly contract amount?

Answer: There was no previous IFB for *Specialized Water Treatment Services with Maintenance and Inspections in Richmond County*. Any previous service had a different set of specifications and is not comparable.

- 2. Question:** Is the cooling tower 300 tons or 300 tons per cell?

Answer: The cooling tower is made up of two (2) cells; it is 300 tons combined.

Respectfully,

Shannon Collings

Shannon Collings, CMS 1,
Contract Management Unit
(845) 877-6821 (Ext 3281)
(845) 877-3044 (fax)
shannon.l.collings@opwdd.ny.gov